



## **Summit Beach Resort Lighting Survey Report**

**The following are the results of the site visit and survey of the Pool Deck that AMA was commissioned to perform.**

**After arriving at the site and performing the survey two additional areas of concern were identified for additional survey requirements. The area's added was an additional Exterior Hot Tub Area and an Interior Hot Tub Room.**

### **Interior Hot Tub**

6.34 Average FC (Footcandles)  
14.5 Max FC  
3.4 Min FC  
4.2/1 Max/Min  
1.9/1 Aver./Min

### **Exterior Hot Tub**

1.8 Average FC (Footcandles)  
7.0 Max FC  
0.2 Min FC  
35/1 Max/Min  
9/1 Aver./Min

### **Main Pool Deck**

0.42 Average FC (Footcandles)  
4.3 Max FC  
0.1 Min FC  
430/1 Max/Min  
42/1 Aver./Min